

DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur
dwtlgsp1@gmail.com

To,

Des Raj Heritage Public School
Aliwal Road, Batala

No.: DWTLGSP/2324/00142 Dated : 29/05/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 5 Dated: 22/05/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 26/05/2023. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Gurdaspur

D/A : Test Report



Authorized Signatory
For, District Water Testing Laboratory,
Gurdaspur

DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur
dwtlgspl@gmail.com



TC-10019

TEST REPORT

Name & Address of Customer : Des Raj Heritage Public School Aliwal Road, Batala	Customer Reference No.	No : 5 Dated : 22/05/2023
	Sample Submitted by	Principal
	Date of Sample Receipt	26/05/2023
	Analysis Starting Date	27/05/2023
	Analysis completion Date	29/05/2023

Discipline : Chemical Testing		Group: Water	
ULR No.:	TC100192300000226F	Sample Type :	Water
Test Report No.:	DWTLGSP/2324/00142	Date of Issue :	29/05/2023
Registration no.:	DWTLGSP/REG2324/00183	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Des Raj Heritage Public School / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Gurdaspur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.6	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
5	TDS	400	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	184	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	192	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	48.09	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	17.49	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	15.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Mr. Pankaj Kumar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory,
Gurdaspur

----- End of the Test Report -----



Har Ghar Jal
Jal Jeevan Mission

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ-1 ਬਟਾਲਾ।

Tele/fax: 01871-500294

e-mail: ewssbatala@yahoo.com
ewssbatala2@gmail.com

ਸੇਵਾ ਵਿਖੇ,

ਜਿਲ੍ਹਾ ਸਿਖਿਆ ਅਫਸਰ,
ਗੁਰਦਾਸਪੁਰ।


ਨੰ: 21/0

ਮਿਤੀ: 25/7/2023

ਵਿਸ਼ਾ ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਬਾਰੇ।

ਹਵਾਲਾ ਆਪ ਜੀ ਦੇ ਦਫਤਰ ਦਾ ਪੱਤਰ ਨੰ: ਜੀ-3/2023/2735 ਮਿਤੀ 21.04.2023


ਹਵਾਲੇ ਅਧੀਨ ਪੱਤਰ ਦੇ ਸਬੰਧ ਵਿਚ **DES RAJ HERITAGE PUBLIC, ALIWAL ROAD, BATALA, DISTT. GURDASPUR** ਵਿਖੇ ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਦੀ ਪ੍ਰੋਵੀਜ਼ਨ ਤਸੱਲੀ ਬੱਖਸ਼ ਪਾਈ ਗਈ ਹੈ। ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਦਾ ਸਰਟੀਫਿਕੇਟ ਮਿਤੀ 26.07.2023 ਤੋਂ 31.03.2024 ਤੱਕ ਇਸ ਸ਼ਰਤ ਤੇ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ ਜੇਕਰ ਇਸ ਸਮੇਂ ਦੌਰਾਨ ਮੁੜ ਚੈਕਿੰਗ ਕਰਨ ਤੇ ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਵਿਚੋਂ ਕੋਈ ਕਮੀ ਪੇਸ਼ੀ ਪਾਈ ਗਈ ਤਾਂ ਇਹ ਸਰਟੀਫਿਕੇਟ ਰੱਦ ਕਰਨ ਦਾ ਹੱਕ ਮਹਿਕਮੇ ਵੱਲੋਂ ਰਾਖਵਾਂ ਹੋਵੇਗਾ।


ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,
ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ,
ਬਟਾਲਾ।

ਪਿਠ ਅੰਕਣ ਨੰ:

ਮਿਤੀ:

ਉਪਰੋਕਤ ਦੀ ਨਕਲ **DES RAJ HERITAGE PUBLIC, ALIWAL ROAD, BATALA, DISTT. GURDASPUR** ਨੂੰ ਸੂਚਨਾਂ ਹਿੱਤ ਭੇਜੀ ਜਾਂਦੀ ਹੈ।


ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,
ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ,
ਬਟਾਲਾ।