

**DISTRICT WATER TESTING LABORATORY, GURDASPUR**

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur  
dwtlgsp1@gmail.com

To,

Des Raj Heritage Public School  
Aliwal Road, Batala

No.: DWTLGSP/2627/00086 Dated : 13/05/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. DPH/2026/903 Dated: 12/05/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 12/05/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Gurdaspur

D/A : Test Report



**Authorized Signatory**  
**For, District Water Testing Laboratory**  
**Gurdaspur**

# DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur  
dwtlgsp1@gmail.com



TC-14032

## TEST REPORT

Name & Address of Customer : <b>Des Raj Heritage Public School</b> Aliwal Road, Batala		Customer Reference No.	No : DPH/2026/903 Dated : 12/05/2026	
		Sample Submitted by	Gurinderpal Singh	
		Date of Sample Receipt	12/05/2026	
		Analysis Starting Date	12/05/2026	
		Analysis completion Date	13/05/2026	
Discipline : <b>Chemical Testing</b>		Group: <b>Water</b>		
ULR No.:	TC14032260000136F	Sample Type :	Water	
Test Report No.:	DWTLGSP/2627/00086	Date of Issue :	13/05/2026	
Registration no.:	DWTLGSP/REG2627/00091	Condition of Sample :	Sealed	
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles	
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Des Raj Heritage Public School Aliwal Road Batala Gurdaspur / 350 ft	
Village :	Not Mentioned	Habitation :	Not Mentioned	
Block:	Not Mentioned	District :	Gurdaspur	
Latitude :	Not Mentioned	Longitude:	Not Mentioned	

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.2@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	240	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO <sub>3</sub> )	120	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO <sub>3</sub> )	128	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	25.65	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	15.55	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	13.99	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr. Pankaj Kumar  
Quality Manager  
Authorized Signatory  
For, District Water Testing Laboratory  
Gurdaspur

End of the Test Report